



## (1) EC-TYPE-EXAMINATION CERTIFICATE (Translation)

(2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - **Directive 94/9/EC**



(3) EC-type-examination Certificate Number:

**PTB 99 ATEX 1057**

(4) Equipment: Control unit type GHG 6.. ....R....

(5) Manufacturer: CEAG Sicherheitstechnik GmbH

(6) Address: D-69412 Eberbach

(7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

(8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 99-19121.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 50014:1997**

**EN 50018:1994**  
**EN 50020:1994**

**EN 50019:1994**

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-type-examination Certificate relates only to the design and construction of the specified equipment in accordance with Directive 94/9/EC. Further requirements of this Directive apply to the manufacture and supply of this equipment.

(12) The marking of the equipment shall include the following:

**II G 2 EEx deia/ib[ia/ib] IIC T6 resp. T5**

Zertifizierungsstelle Explosionsschutz

Braunschweig, September 01, 1999

By order:

Dr.-Ing. U. Klausmeyer  
Regierungsdirektor



sheet 1/3

EC-type-examination Certificates without signature and official stamp shall not be valid. The certificates may be circulated only without alteration. Extracts or alterations are subject to approval by the Physikalisch-Technische Bundesanstalt. In case of dispute, the German text shall prevail.

## SCHEDULE

(13)

(14) **EC-TYPE-EXAMINATION CERTIFICATE PTB 99 ATEX 1057**

(15) Description of equipment

The type GHG 6.. ...R... control unit is composed of enclosures of the type of protection flameproof enclosure "d", optionally with operation rods and/or inspection windows into which the electrical equipment is incorporated.

Direct cable entries, conduit entries (conduit system) or terminal boxes of the type of protection increased safety "e", for which a separate test certificate has been issued, are used for connection.

### Electrical data

Rated insulation voltage .....	up to	275 V	750 V	10 kV
Rated current .....	max.		630 A	
Rated cross-section .....	max.		330 mm <sup>2</sup>	

If and when required, equipment of the type of protection intrinsic safety "i" is incorporated, for which a separate test certificate has been issued.

The rated values are maximum values, the actual electrical values depend on the electrical equipment incorporated. Within the scope of these maximum permissible values and with due regard to the standards applicable, the manufacturer specifies the final rated values dependent on the system conditions, mode of operation, utilization category, etc. The characteristic values of the intrinsically safe circuits are to be given by the manufacturer on his own responsibility. Further technical details have been specified in the test documents.

The composition of the symbol specifying the type of protection depends on the types of protection of the components used.

(16) Report PTB Ex 99-19121, description (6 sheets), 6 drawings

(17) Special conditions for safe use

The control unit may also be connected via suitable cable entries or conduit entries which meet the requirements of EN 50 018, sections 13.1 and 13.2 and for which a separate certificate has been issued.

Openings which are not used are to be sealed in accordance with EN 50 018, section 11.

sheet 2/3

Equipment of the type of protection intrinsic safety "i" is to be installed in such a way that the distances, creepage distances and clearances between intrinsically safe circuits and non-intrinsically safe circuits required according to EN 50 020 are complied with.

If the distances required according to EN 50 020 for connection facilities are not ensured by the installation, cables of increased safety "e" quality or fail-safe cables are to be used.

When more than one intrinsically safe circuit is used, the rules for interconnection are to be observed.

(18) Essential health and safety requirements

The tests carried out and their positive results show that the control unit complies with the requirements of Directive 94/9/EC and of the standards stated on the cover sheet.

Zertifizierungsstelle Explosionsschutz

Braunschweig, September 01, 1999

By order:

Dr.-Ing. U. Klausmeyer  
Regierungsdirektor

